



**NOTICE TO ALL PROSPECTIVE RESPONDENTS
RFP 22-MRILMC/LN**

Addendum No. 2 issued February 11, 2022

RFI 1: Please provide nurse’s call system equipment model, location and service provider information.

Response: ***Nurse Emergency Call Equipment - Ascom.***
Service provider – ADT 772-529-0591 Josephvarallo@adt.com (Robert)
Show this work as an **ADD Option**

Gas/ Alarm Panel- ADD OPTION-

The existing medical gas alarm panel does not have spare slots. Therefore, we may/ will need to add a new panel adjacent to that one to monitor medical gasses in the Modular MRI. (located in the Nurse’s station) This is not required by AHCA therefore is an add option

RFI 2: Please provide Siemens representative contract information for the facility

Response: ***Jorge Rodermund***
Cell – 954-410-1586 Office – 954-364-6600
jorg.rodermund@siemens.com

RFI 3: Please provide contract for Access Control vendor if we are to complete that portion of the project.

Response: ***Johnson Control – Angela Nelli 978-790-6784 Angela.M.Nelli@jci.com***

I acknowledge receipt of Addendum No. 1 to RFP 22-MRILMC/LN, dated 2/11/2022.

(Name of Company)

(Authorized Representative’s Name)

(Dated Signature)